

HSE Bulletin 46 in 2019

Changes in generator emissions - requirements for London sites

Date of issue: 23 December 2019

Background

TfL requires that all Non Road Mobile Machinery (any mobile machine or vehicle that is not solely intended for carrying passengers or goods on the road) that is used in its construction, demolition and maintenance works must meet or exceed the Non Road Mobile Machinery (NRMM) emission standards set out in the emission requirements of the Greater London Authority's NRMM Low Emission Zone.

Instruction

From 1 January 2020 all constant-speed engines, such as those typically found in generators, are required to meet Emissions Stage V throughout London either by technology or by retrofit for both NO_x (nitrogen oxides) and PM (particulate matter) reduction. This applies to generators of net power of between 37kW and 560kW.

TfL and its contractors must make sure that equipment used on sites after 1 January 2020 is compliant with the revised standards.

For further guidance on how to comply visit <https://nrmm.london/> or contact environment@tfl.gov.uk.

For more information contact:	Jo Powis, Environment Manager
Approved by:	Helen Woolston, Senior HSE Manager
